

ValveMeter Lite System shown w/ a Model 115-3 Valve

THEORY OF OPERATION

ValveMeter Lite with an OCV Control Valve The ValveMeter Lite System will measure the valve degree of opening (CV), and the differential pressure (DP) across the valve, and then calcu-late the water flow (Q) thru the valve using the formula listed below. By mounting and calibrat-ing the Model 190 Position Transducer and the Model 210 Differential Pressure Transducer-the electronics-can then measure the valve position. From this information, the electronics unit calcu-lates the Cv of the valve from an internal table of the selected valve. After the Cv has been com-puted, the Differential Pressure (DP) is measured and the formula below is used to calculate the flow through the valve. flow through the valve. DP SG

$$Q = C_v \int \frac{1}{5}$$

Whereas: Q = Flow in GPM

- Cv = Coefficient of Valve (in Gallons)DP = Differential Pressure (PSI)
- SG= Specific Gravity of Fluid
- (Water = 1.0)

After the flow has been calculated, the electron-ics unit then converts the flow to the selected scaling and then displays the flow. At one second intervals the 4-20mA analog out-put is updated to the current flow rate.

SYSTEM COMPONENTS

The ValveMeter Lite System consists of three

ValveMeter Electronics Unit: This device is the heart of the flow measurement system and provides power to the other units needed.
Model 190 Position Transducer: This unit is attached to the valve bonnet visual stem port and is used to measure the amount of valve popping.

opening. 3.) Model 210 Differential Pressure Transducer: This unit is attached to the valve on the back side, and is used to measure the difference between the input and output of the valve.

*Note-This system does not include a control valve. It is designed as an accessory to add to an OCV control valve when the application requires flow measurement information. The ValveMeter Lite may be added to an existing OCV control valve (any OCV valve that is 4" or larger).

How to order your VML System

When Ordering please provide: Fluid to be controlled - Model Number - Size - Globe or Angle - Controller Voltages - Controller Options - Special Requirements / Installation Requirements

The ValveMeter Lite (VML) is an electronic flow measurement system that can be added to any OCV control valve, ranging from 4" to 24". By adding this system, the electronic unit will give the ability to measure flow through the adapted valve. As a result, the user may access this information any of the following ways:

- 1.) Digital display on the front of the ValveMeter Lite electronics unit 2.) The unit will translate the flow to a 4-20mA analog output that is scaled to the
- maximum flow of the valve selected (20 feet/sec rate)
- 3.) Digital output (RS232) for the flow rate, totalizer count, measurement scale, and other information

Typical examples include:

•Water transmission lines •Water treatment plants •Pump stations

Note: For clarification of electronic terminology refer to the OCV Electronic Glossary **Valves 1-1/4" through 24" are certified to NSF/ANSI 372. Valves 4" through 24" are also certified to NSF/ANSI 61-G.

MODEL FEATURES KER Carrol Dates Overall accuracy of +/- 2% Sizes 4"-24" User-friendly screen operation User-selectable flow units (USGPM, m3/hr, L/S, MGD) by internal DIP switch 2) 4-20 mA output of metered flow rate Includes totalizer (sums) the total number of gallons that FLOW RATE OUTPUT FLOW have flowed through the ITEM DESCRIPTION 1 VALVEMETER LITE valve since the totalizer POSITION TRANSMITTER 3 DIFFERENTIAL PRESSURE reset. Measured TRANSMITTER in USGPM, m3/hr, 4 ISOLATION BALL VALVE 3 L/S or MGD) BASIC VALVE ASSEMBLY* 5

- RS232
- communications 100-260Vac 50-60Hz with 24/12 VDC, or solar
- powered units available Optional
- ► Configuration for low pressure operation
- ► Consult factory for others

CONTROLLER **SPECIFICATIONS**

Power Requirements: 100-260 VAC 50-60Hz standard; Optional 24VDC or 12VDC **Inputs From Transducers:** 4-20 mA standard **Panel Dimensions:** 6-3/4" (172mm) High x 4-3/4" (121mm) Wide x 2-3/8" (60.3mm) Déep Ènclosuré: Nema 4X (weather tight, corrosion resistant) Application Enginéering Assistance: Consult Factory

*Note: valve may be any OCV control valve from 4" to 24". Valve is sold seperately from VML System.

VML SPECIFICATIONS

(Typical Water Application)

The electronic flow measurement system shall operate to measure the flow rate without the use of external flow transducer.

DESIGN

The electronic flow measurement system shall consist of the valve position transmitter and valve differential transmitter and shall be adapted to the valve assembly. The measurement unit (electronics) shall be furnished separately for remote installation at a convenient location. The electronic flow system shall be operationally tested prior to shipment.

MATERIALS OF CONSTRUCTION

The measurement system shall be of weatherproof enclosures and be suitable for operation on . <voltade>

OPERATING CONDITIONS

The electronic flow measurement system shall be suitable for pressures of $\langle X$ to $\dot{X} \rangle$ psi, measuring flow rates up to $\langle X \rangle$ gpm. **ACCEPTABLE PRODUCTS**

The electronic measurement system shall be mounted on a <size> OCV Control Valve, as manufactured by OCV Control Valves, Tulsa, Oklahoma, USA.

aivemeter Lite Flow Measuren TOLL FREE 1.888.628.8258 • phone: (918)627.1942 • fax: (918)622.8916 • 7400 East 42nd Place, Tulsa, 0k 74145 REVISED 05/04/17

ValveMeter Lite System

(1)

__120 VAC

4-20 mA

email: sales@controlvalves.com • website: www.controlvalves.com **Global** performance. **Personal** touch.