



Model 115-2 (Terminal Services) METRIC



The Model 115-2 has an extremely wide range of applications: anywhere it is necessary to open and close a valve electrically. Typical examples include:

- ► Process control
- ► Petroleum loading terminals
- Storage tank level control

SERIES FEATURES

- Electrically operated solenoid allows valve to open or close
- ► Can be maintained without removal from the line
- ► Adjustable response speed
- Factory tested and can be pre-set to your requirements

OPERATION

A two-way solenoid, when closed, causes the main valve to close. Opening the solenoid opens the valve. The pilot system is equipped with a needle valve that allows the opening and closing speed of the valve to be adjusted.


The solenoid can be supplied normally closed (energize to open) or normally open (energize to close).

COMPONENTS

The Model 115-2 consists of the following components, arranged as shown on the schematic diagram:

- 1.) Model 65 Basic Control Valve
- 2.) Model 451 Two-Way Solenoid Pilot
- 3.) Model 126 Ejector
- 4.) Model 141-2 Needle Valve
- 5.) Model 123 Inline Strainer

SCHEMATIC



RECOMMENDED INSTALLATION

- Install the valve with adequate space above and around the valve to facilitate servicing. Refer to the Dimension Table.
- ► Valve should be installed with the bonnet (cover) at the top, particularly 8" (DN200) and larger valves, and any valve with a limit switch.
- Shut-off valves should be installed upstream and downstream of the control valve. These are used to isolate the valve during start-up and maintenance.
- Following main valve installation, the solenoid must be wired into the user's control system. This is a simple two-wire (plus ground) connection.

SIZING

Definitive sizing information can be found in the Series 115 section of the OCV Catalog and Engineering section Performance Charts. Consult the factory for assistance.

MAX. PRESSURE

(The pressures listed here are maximum working pressures at 37.78°C)

END CONNECTIONS	DUCTILE IRON	STEEL WCB	STEEL LCB	STN. STL.	ALUMINUM
Threaded	44.1 bar	44.1 bar	44.1 bar	44.1 bar	19.7 bar
Grooved	20.7 bar	20.7 bar	20.7 bar	20.7 bar	13.8 bar
150# Flanged	17.2 bar	19.7 bar	18.4 bar	19.0 bar	19.7 bar
300# Flanged	44.1 bar	51.0 bar	48.0 bar	49.6 bar	

Note: Working pressures of solenoids vary greatly, consult factory on application of OCV Model 115-2 valves.

MAXIMUM FLUID FLOW

SIZE (MM)			DN40	DN50	DN65	DN80	DN100	DN150	DN200	DN250	DN300	DN350	DN400	DN450	DN500	DN600
2.29 M/SEC (MILITARY)	MAX	9	11	18	27	41	68	154	272	420	602	726	942	1192	1487	2134
4.57 M/SEC (MAX RECOMMENDED)	FLOW	16	23	36	52	79	136	306	533	840	1192	1441	1884	2384	2974	4268
6.10 M/SEC (MAX CONTINUOUS)	(M3/HR)	23	30	48	68	107	182	409	715	1124	1589	1918	2520	3178	3950	5698

U.S. Military valves cannot exceed a max velocity of 2.29 m/sec. Max recommended fluid flow for petroleum fluids is 4.57 m/sec. Max continuous flow for all fluids is 6.10 m/sec.

phone: (918)627.1942 • fax: (918)622.8916 • 7400 East 42nd Place, Tulsa, OK 74145

email: sales@controlvalves.com • website: www.controlvalves.com

Model 115-2 (Terminal Services) METRIC





SIZES GLOBE/ANGLE

Screwed Ends -

LE 1 1/4" - 3" (DN32 thru DN80) 1 1/2" - 6" (globe) (DN40 thru DN150) 1-1/2" - 6" (angle) (DN40 thru DN150) 1 1/4" - 24" (globe) (DN32 thru DN600) 1 1/4" - 16" (angle) (DN32 thru DN400) Grooved Ends -Flanged Ends -

FLUID OPERATING TEMPERATURE RANGE (Valve Elastomers)

Buna-N -40°C to 82.22°C Viton -6.67°C to 110°C Fluorosilicone -40°C to 65.56°C EPDM -17.78°C to 110°C

MATERIALS Consult factory for others.

Body/Bonnet: Ductile Iron (epoxy coated), Carbon Steel (epoxy

coated), Stainless Steel, Aluminum Seat Ring: Stainless Steel, Bronze Stem: Stainless Steel, Monel

Spring: Stainless Steel

Diaphragm: Buna-N, Viton, (Nylon reinforced)

Seat Disc: Buna-N, Viton Pilot: Stainless Steel, Bronze Other pilot system components: Stainless Steel. Bronze/Brass

Tubing & Fittings: Stainless Steel, Copper/Brass

SOLENOID

Enclosure: Explosion Proof NEMA 4X, 6P, 7, 9

Body: Stainless Steel, Brass **Voltages:** 24, 120, 240, 480 VAC 12, 24 VDC

Note: Working pressures of solenoids vary greatly, consult fac-

tory on application of OCV Model 115-2 valves.

SPECIFICATIONS (Typical Terminal Services Application)

The solenoid shut-off valve shall open and close via discrete electrical signals. The valve shall be equipped with a two-way solenoid valve that will allow the valve to open when <energized, deenergized>.

The solenoid valve shall be a single-seated, line pressure operated, diaphragm actuated, pilot controlled globe valve. The valve shall seal by means of a corrosion-resistant seat and a resilient, rectangular seat disc. These, and other parts, shall be replaceable without removing the valve from the line. The stem of the main valve shall be guided top and bottom by integral bushings. Alignment of the body, bonnet and diaphragm assembly shall be by precision dowel pins. The diaphragm shall not be used as a seating surface, nor shall the pistons be used as an operating means. The pilot system shall be furnished complete and installed on the main valve. It shall include a needle valve, inline strainer and solenoid valve. The solenoid shut-off valve shall be operationally and hydrostatically tested prior to shipment.

MATERIALS OF CONSTRUCTION

The main valve body and bonnet shall be ductile iron. All ferrous surfaces shall be coated with 4 mils of epoxy. The main valve seat ring shall be stainless steel. Elastomers (diaphragms, resilient seats and O-rings) shall be Buna-N. The needle valve and control line tubing shall be stainless steel. The solenoid shall have a stainless steel body, explosion-proof enclosure and be suitable for operation on <voltage>

OPERATING CONDITIONS

The solenoid shut-off valve shall be suitable for pressures of <X to X> bar at flow rates up to <X> m₃/hr.

ACCEPTABLE PRODUCTS

The solenoid shut-off valve shall be a <size> Model 115-2, <globe pattern, angle pattern>, with <150# flanged, 300# flanged, threaded, grooved> end connections, as manufactured by OCV Control Valves, Tulsa, Oklahoma, USA.

METRIC DIMENSIONS - M.M.

DIM	END CONN.	DN32-DN40	DN50	DN65	DN80	DN100	DN150	DN200	DN250	DN300	DN350	DN400	DN600
Α	SCREWED	222	251	267	330	##S			mar.	***			250
	GROOVED	222	251	267	330	387	508	1222	227	7922	122	620	722.0
	150# FLGD	216	238	267	305	381	451	645	756	864	991	1026	1575
	300# FLGD	222	251	283	324	397	473	670	791	902	1029	1067	1619
C ANGLE	SCREWED	111	121	152	165		199	-	++	SHE	177	77	
	GROOVED	111*	121	152	165	194	944	-			(99)		
	150# FLGD	108	121	152	152	191	254	322	378	432		529	
	300# FLGD	111	127	162	162	198	267	335	395	451	120	549	35 <u>22</u> 8
D ANGLE	SCREWED	79	98	102	114			-			377		
	GROOVED	79*	98	102	114	143		100		88-10	(me)	755	Geo.
	150# FLGD	76	98	102	102	140	152	203	289	279	(++)	398	
	300# FLGD	79	105	111	111	148	165	216	306	298		419	***
E	ALL	152	152	178	165	203	254	302	391	432	457	483	686
F	ALL	98	98	98	98	98	98	162	162	162	162	162	203
Н	ALL	254	279	279	279	305	330	356	432	457	508	508	724

^{*}GROOVED END NOT AVAILABLE IN DN32

CE Markings
Applies to fuel valves installed in the European Union in accordance with the Pressure Equipment Directive, 97/23/EC
CE-marked valves are available in LCB steel and CF8M stainless steel only OCV is registered to the PED through Det Norske Veritas

The following valves will be CE-marked:

6" (DN150) and larger valves, 150# and 300# class, liquid fuel only

2" (DN50) thru 4" (DN100) valves, 300# class, liquid fuel

1 1/4" (DN32) thru 4" (DN100) valves, 300# class, LPG or Butane service
 4" (DN100) and smaller valves in Class 150# (liquids) are furnished under SEP with no CE-mark

For maximum efficiency, the OCV control valve should be mounted in a piping system so that the valve bonnet (cover) is in the top position. Other positions are acceptable but may not allow the valve to function to its fullest and safest potential. In particular, please consult the factory before installing 8" (DN200) and larger valves, or any valves with a limit switch, in positions other than described. Space should be taken into consideration when mounting valves and their pilot systems.

A routine inspection & maintenance program should be established and conducted yearly by a qualified technician. Consult our factory @ 1-918-627-1942 for parts and service.

How to order your Model 115-2 valve

When ordering please provide:

Fluid to be controlled - Model Number - Size - Globe or Angle - End Connection Body Material - Trim Material - Solenoid Voltage - Energize to Open or Close
Valve - Special Requirements / Installation Requirements

phone: (918)627.1942 • fax: (918)622.8916 • 7400 East 42nd Place, Tulsa, Oklahoma 74145

email: sales@controlyalves.com • website: www.controlyalves.com

