







**Fueling** 



Terminal Services

#### Excess Flow Shut-Off Valve



The excess flow shut-off valve shall close when the flow rate set point is exceeded. Manual reset shall be required to re-open the valve. The OCV 128 can be employed anywhere excessive flow rates must be positively prevented. It is particularly useful as a protective device against downstream line rupture.

# Certification & Compliance

NSF-ISO Quality System (9001)



ABS Type Approval



Technical Standards & Safety Authority



American-Made: American Recovery & Reinvestment



Pressure Equipment Directive Certified 2014/68/EU



CE (Conformité Européenne) Compliance



#### Features & Benefits

- Valve trips closed when predetermined flow rate is detected
- Built-in orifice plate for sensing flow rate
- Valve must be manually reset to re-open
- Flow rate is adjustable with single screw
- Adjustable response speed
- Can be maintained without removal from the line
- Factory tested and can be preset to your requirements

# Typical Applications

Metering Systems



Loading Terminals



Storage Tanks



Truck/Rail Car Loading & Unloading Systems



# Aquestia Directing the Flow

Truck/Rail Car Loading & Unloading Systems




The latched open, spring loaded pilot, sensing the differential across the integral orifice plate, located in the valve inlet flange, remains open as long as the flow rate is below a predetermined trip point. If flow rate rises to the trip point, the pilot closes, causing the main valve to close. The pilot remains closed until manually reset by pushing the reset button on the end of the pilot.



The OCV 128 consists of the following components, arranged as shown on the schematic diagram:

- 1 Model 65 Basic Valve (fail closed)
- 2 Orifice Plate
- 3 Model 1380 Excess Flow Pilot
- 4 Model 126 Ejector
- 5 Model 141-2 Needle Valve
- 6 Model 123 Inline Strainer
- 7 Model 155 Visual Indicator (optional)



## Pressure Table

End Connections	Ductile Iron	Ductile Iron   STEEL/SST		STEEL WCB	Aluminum				
Standard (Maximum Working Pressures at 100°F)									
Screwed	640 psi	640 psi			285 psi				
Grooved	300 psi	300 psi			200 psi				
150# Flanged	250 psi	285 psi			285 psi				
300# Flanged	640 psi	740 psi							
Metric (Maximum Wo	rking Pressures	at 37.78°C)							
Screwed	44.1 bar	44.1 bar	44.1 bar	44.1 bar	19.7 bar				
Grooved	20.7 bar	20.7 bar	20.7 bar	20.7 bar	13.8 bar				
150# Flanged	17.2 bar	19.0 bar	18.4 bar	19.7 bar	19.7 bar				
300# Flanged	44.1 bar	49.6 bar	48.0 bar	51.0 bar					

Based on ANSI flange ratings.







Standard Size Max. Flow (GPM)	1 1/4"	1 ½"	2"	2 ½"	3"	4"	6"	8"	10"	12"	14"	16"	18"	20"	24"
7.5 FT/SEC (Military)	40	50	80	120	180	300	680	1200	1850	2650	3200	4150	5250	6550	9400
15 FT/SEC (Max. Recommended)	70	100	160	230	350	600	1350	2350	3700	5250	6350	8300	10500	13100	18800
20 FT/SEC (Max. Continuous)	100	130	210	300	470	800	1800	3150	4950	7000	8450	11100	14000	17400	25100
Metric Size Max. Flow (m³/hr)	DN32	DN40	DN50	DN65	DN80	DN100	DN150	DN200	DN250	DN300	DN350	DN400	DN450	DN500	DN600
2.29 M/SEC (Military)	9	11	18	27	41	68	154	272	420	602	726	942	1192	1487	2134
4.57 M/SEC (Max. Recommended)	16	23	36	52	79	136	306	533	840	1192	1441	1884	2384	2974	4268
6.10 M/SEC (Max. Continuous)	23	30	48	68	107	182	409	715	1124	1589	1918	2520	3178	3950	5698

The OCV 128 is normally sized to match the meter size; however, in no case should the maximum velocity exceed 20 ft/sec (metric: 6.10 meters/sec).

Resetting, maintenance and periodic testing instructions must be followed as described in detail in the applicable OCV IOM (Installation, Operation & Maintenance) Manual.

## Typical Materials

Part	Standard Material
Body/Bonnet	Ductile Iron (epoxy coated), Carbon Steel (epoxy coated), Stainless Steel, Aluminum
Seat Ring	Stainless Steel, Bronze
Stem	Stainless Steel, Monel
Spring	Stainless Steel
Diaphragm	Buna-N, Viton (Nylon reinforced)
Seat Disc	Buna-N, Viton
Pilot	Stainless Steel, Bronze
Other Pilot System Components	Stainless Steel, Bronze/Brass
Tubing & Fittings	Stainless Steel, Copper/Brass







#### General Arrangement & Dimensions


Standar	d Sizes												
DIM	END CONN.	1 1/4 - 1 1/2"	2"	2 1/2"	3"	4"	6"	8"	10"	12"	14"	16"	24"
	SCREWED	8 3/4	9 7/8	10 1/2	13								
_	GROOVED	8 3/4	9 7/8	10 1/2	13	15 <sup>1</sup> / <sub>4</sub>	20						
A	150# FLGD	8 1/2	9 3/8	10 1/2	12	15	17 3/4	25 3/8	29 3/4	34	39	40 3/8	62
	300# FLGD	8 3/4	9 7/8	11 <sup>1</sup> / <sub>8</sub>	12 3/4	15 5/8	18 5/8	26 <sup>3</sup> / <sub>8</sub>	31 1/8	35 1/2	40 1/2	42	63 3/4
	SCREWED	43/8	4 3/4	6	6 1/2								
С	GROOVED	4 3/8*	4 3/4	6	6 1/2	7 5/8							
ANGLE	150# FLGD	4 1/4	4 3/4	6	6	71/2	10	12 11/16	14 <sup>7</sup> / <sub>8</sub>	17		20 13/16	
	300# FLGD	4 3/8	5	6 3/8	6 3/8	7 13/16	10 1/2	13 3/16	15 <sup>9</sup> / <sub>16</sub>	17 3/4		21 5/8	
	SCREWED	3 1/8	3 7/8	4	4 1/2								
D	GROOVED	3 1/8 *	3 7/8	4	4 1/2	5 5/8							
ANGLE	150# FLGD	3	3 7/8	4	4	5 1/2	6	8	11 <sup>3</sup> / <sub>8</sub>	11		15 11/16	
	300# FLGD	3 1/8	4 1/8	4 3/8	4 3/8	5 <sup>13</sup> / <sub>16</sub>	6 1/2	8 1/2	12 1/16	11 3/4		16 <sup>1</sup> / <sub>2</sub>	
Е	ALL	6	6	7	6 1/2	8	10	11 <sup>7</sup> /8	15 <sup>3</sup> / <sub>8</sub>	17	18	19	27
F (OPT)	ALL	3 7/8	3 7/8	3 7/8	3 7/8	3 7/8	3 7/8	6 3/8	6 <sup>3</sup> / <sub>8</sub>	6 3/8	6 3/8	6 <sup>3</sup> / <sub>8</sub>	8
Н	ALL	10	11	11	11	12	13	14	17	18	20	20	28 1/2

Metric S	iizes												
DIM	END CONN.	DN32-40	DN50	DN65	DN80	DN100	DN150	DN200	DN250	DN300	DN350	DN400	DN600
	SCREWED	222	251	267	330								
_	GROOVED	222	251	267	330	387	508						
A	150# FLGD	216	238	267	305	381	451	645	756	863	991	1026	1575
	300# FLGD	222	251	283	324	397	473	670	791	902	1029	1067	1619
	SCREWED	111	121	152	165								
С	GROOVED	111*	121	152	165	194							
ANGLE	150# FLGD	108	121	152	152	191	254	322	378	432		529	
	300# FLGD	111	127	162	162	198	267	335	395	451		549	
	SCREWED	79	98	102	114								
D	GROOVED	79*	98	102	114	143							
ANGLE	150# FLGD	76	98	102	102	140	152	203	289	279		398	
	300# FLGD	79	105	111	111	148	165	216	306	298		419	
Е	ALL	152	152	178	165	203	254	302	391	432	457	483	686
F (OPT)	ALL	98	98	98	98	98	98	162	162	162	162	162	203
Н	ALL	254	279	279	279	305	330	356	432	457	508	508	724

<sup>\*</sup>Grooved End not available in 1 1/4" (DN32).











## Technical Data

Temperature (Elastomers)							
Buna-N	-40°F to 180°F						
Viton	20°F to 230°F						
Fluorosilicone	-40°F to 150°F						
EPDM	0°F to 230°F						
Sizes							
Screwed Ends	1-1/4" - 3"						
Grooved Ends	1-1/2" - 6" (globe & angle)						
Flanged Ends	1-1/4" - 24" (globe); 1-1/4" - 16" (angle)						
Pressure Rating (ANSI	at 100°F)						
250psi for Class 150# ANSI Flanged Ductile Iron							
285psi for Steel/Stair	lless Steel & Aluminum						
300# ANSI Flanges ar	300# ANSI Flanges are available						
Solenoid Voltage							
Enclosure	Explosion Proof NEMA 4X, 6P, 7, 9						
Body	Brass, Stainless Steel						
Voltages	24, 120, 240, 480 VAC; 12, 24 VDC						

Body & Cover Material
Ductile Iron
Carbon Steel
Stainless Steel
Aluminum
Trim Material
Bronze/Brass
Stainless Steel
Copper
Optional Components
Two-Stage Opening
Visual Indicator
Pre-Wired Junction Box
Items to Specify
Fluid Type
Model Number
Size
Body & Trim Material
Solenoid Voltage
Globe or Angle
Special Installation Requirements

# Engineering Specifications

The excess flow shut-off valve shall be a single-seated, line pressure operated, diaphragm actuated, pilot controlled globe valve. The valve shall seal by means of a corrosion-resistant seat and a resilient, rectangular seat disc. These, and other parts, shall be replaceable without removing the valve from the line. The stem of the main valve shall be guided top and bottom by integral bushings. Alignment of the body, bonnet and diaphragm assembly shall be by precision dowel pins. The diaphragm shall not be used as a seating surface, nor shall the pistons be used as an operating means. The orifice plate shall be integrally installed in the valve inlet flange. The pilot system shall be furnished complete, installed on the main valve and include a needle valve speed control and an inline strainer. The excess flow shut-off valve shall be operationally and hydrostatically tested prior to shipment. The main valve body and bonnet shall be ductile iron. All ferrous surfaces shall be coated with 4 mils of epoxy. The main valve seat ring shall be stainless steel. Elastomers (diaphragms, resilient seats and o-rings) shall be Buna-N. The control pilot shall be stainless steel, while the opening speed control and control line tubing shall be stainless steel. The orifice plate shall also be stainless steel. The excess flow shut-off valve shall be suitable for operation at <X> psi (see Pressure Table) at flow rates up to <X> gpm (see Flow Chart). The excess flow shut-off valve shall be an OCV 128, as manufactured by OCV, Tulsa, OK, USA.

Aquestia Ltd. reserves the right to make product changes without prior notice. To ensure receiving updated information on parts specifications, please contact us at usa@aquestia.com. Aquestia Ltd. shall not be held liable for any errors.

